



	A	B	E	F	G	H	L	M	N
DIMENSIONS (IN INCHES)	8	11 3/4	7/8	11 1/8	5 1/2	17 5/8	4 1/2	7	3/4

NOTES:

1. AWWA C509 RESILIENT SEATED GATE VALVE MAY BE SUBSTITUTED FOR STORMWATER VALVE PER ENGINEER'S APPROVAL.
2. CONSTRUCT FLOW RESTRICTOR TO ACCOMMODATE 8" FLANGE CONNECTION FOR VALVE. MAY USE 8" X OUTLET PIPE DIAMETER FLANGED REDUCER OR ACCEPTED EQUIVALENT.

Gary M. Schimek

APPROVED BY: GARY M. SCHIMEK
NATURAL RESOURCES/STORMWATER ENGINEERING MANAGER

REVISION DATE: MARCH 01, 2017



STANDARD DETAILS

STORMWATER GATE
VALVE

FILE NAME: SD611.DWG

DETAIL NUMBER: 611